




Building Technology

Tucson, Arizona


Junha and Vincent

Overall Design on Site



Location

Koppen Climate Map



Tucson, AZ

Arrid Steppe Hot (BSh)
ASHRAE Climate Zone 2 (Hot)

Site Location


City Map

Downtown




Local Microclimate

Diaurnal Averages - Wind Rose



Entire Year | Whole Day | > Calm 0 m/s | -2 - 44°C | 0% - 100% humidity
Total 8760 hrs | Medium Speed 3,1 m/s
Tucson.Intl.AP


- Calm(0 m/s)
- Light Air(0,3 m/s)
- Light Breeze(1,6 m/s)
- Gentle Breeze(3,4 m/s)
- Moderate Breeze(5,5 m/s)
- Fresh Breeze(8 m/s)
- Strong Breeze(10,8 m/s)
- Near Gale(13,9 m/s)
- Gale(17,2 m/s)




Significant Daily Temperature Swings (Delta T: 10 to 16°C)
Predominant SE Wind
Summer Monsoon
High Solar Radiation throughout the year

Design Principles

Environmental Concepts




Overall Massing on Site



Size: 5050 m2
Type: Two-storey office building


Shading Study

Massing Test - 5050 m²



Energy Target

EUI



EUI Goal

32 kBTU
100 kWh

200% Solar Energy Building

Daylight Concept

Central Curved Opening and Skylights



Daylight Precedents

Curved Opening, Light Wells, Elevation Change



Rolex Center - SAANA - Lausanne




Kanagawa Institute of Technology - Ishigami


Daylight Massings

3 Concepts





Option 01
Curved Opening



Option 02
Courtyards




Option 03
Ramp + Skylights




Daylight Massing Studies

Climate Studio Simulations

Option 01
Curved Opening




sDA = 100 %




ASE = 33.1 %

Option 02
Courtyards




sDA = 99.9 %




ASE = 46.6 %

Option 03
Ramp + Skylights



sDA = 95.1 %




ASE = 48 %


Daylight Massing Studies

Climate Studio Simulations

Option 01
Curved Opening




sDA = 100 %




ASE = 33.1 %

Option 02
Courtyards




sDA = 99.9 %




ASE = 46.6 %

Option 03
Ramp + Skylights



sDA = 95.1 %




ASE = 48 %



Facades & Shading Systems

Overhang Roof, Skylights, Louvers



Iteration 01
40% WWR



Iteration 02
Overhang + Skylights




Iteration 03
Louvers



Facades & Shading Systems


Climate Studio Simulations

Iteration 01
40% WWR




sDA = 72.1%

Iteration 02
Overhang + Skylights




sDA = 84.0 %


Iteration 03
Louvers




sDA = 81.6 %



ASE = 12.3 %



ASE = 12.0 %




ASE = 4.6 %




Louvers

ON/OFF



Louvers ON

ASE = 4.6 %





Louvers OFF

ASE = 12.0 %

Glare Analysis

Improved Massing

sDG = 7.8%




Glare Analysis

Visual Comfort Comparison

Sept 10 Midday 12:00


sDG = 7.4%



No shading on the skylight

Intolerable Glare

Ev = 4,566 lux, DGP = 0.74











Shading on the skylight

Imperceptable Glare

Ev = 726 lux, DGP = 0.27

Electric Lighting

Layout & LPD

Type and wattage	Perspective	Luminance intensity distribution	Wattage	Location
Linear Suspended Strip Diffuse Lens 8' 103W 10240 lm			103W	Office Wings (Zone 1)
L27600 AOK Series - LED Adjustable Vaportite (L27696-90W-AOK-S5_90W50K)			90W	Central Office 1st floor (Zone 2)
Circular Downlight 8-inch 85W 5830 lm			85W	Corridors/Circulation Areas (Zone 3)
Linear Suspended Strip Diffuse Lens 8' 103W 10240 lm			103W	Lounge (Zone 4)






Zone 01: 74 x 103W
 Zone 02: 40 x 90W
 Zone 03: 64 x 85W
 Zone 04: 20x 103W

LPD for our building: $(74 \times 103 + (40 \times 90) \times 2 + 64 \times 85 + 20 \times 103) \text{ W} / 5310 \text{ m}^2 = 4,2 \text{ W} / \text{m}^2$

4,2 W/ m²

Point-in-time Illuminance

Sept 10 Evening 19:00




mean lux = 310



median lux = 262

There are in total of 198 lighting specs distributed across the large floor plan, which seems a lot. While the floor plan seems well artificially lit, further optimization could look at alternative distributions and locations of the luminaires.


Inside Renders



Exterior Renders




Energy Concept



Thermal Study

Zones - Baseline Design




Goal

Site EUI = 154

Site EUI = 100


KWh/m²

Key Iterations




1. Occupancy

Upgrade Description



$$410 \text{ people} / 5310 \text{ m}^2 = 0.07721281 \text{ P/m}^2$$



3days week for 5 months

Upgrade Performance

Site EUI = 171

KWh/m²

2. Reduced Loads

Upgrade Description

▼  Equipment

6.16

Equipment Power Density [W/m²]

MediumOffice-2B_BLDG_EQUIP_SCH_Year

Equipment Availability Schedule

▼  Lighting

2.94

Lighting Power Density [W/m²]

MediumOffice-2B_3daysfor5months

Lights Availability Schedule

300

Illuminance Target [Lux]

Continuous

DimmingType


Upgrade Performance

Site EUI = 121

KWh/m²

3.Rammed Earth

Upgrade Description



MediumOffice-2B_RammedEarth

U-Value[W/(m²·K)] = 0.329
R-Value[m²K/W] = 2.866
Thermal Capacitance[kJ/K/m²] = 1300.59
Embodied Energy[MJ/m²] = 64
Embodied Carbon[kgCO₂/m²] = 22.935

Layers: (Outside - Inside)

- 1 - MediumOffice-2B_WOOD SIDING 0.01 [m]
- 2 - Rammed Earth 0.25 [m]
- 3 - Cork 0.1 [m]
- 4 - Rammed Earth 0.25 [m]
- 5 - defaultMat 0.25 [m]



Tucson Mountain Retreat by DUST



Tucson Vernacular Adobe Construction

Upgrade Performance


Site EUI = 115

KWh/m²

4.Natural Ventilation

Upgrade Description

Solar Chimney



Upgrade Performance

Microclimate

Roof Shading





Louvers

Site EUI = 94

KWh/m²

HVAC Design

VRF Overall Layout




PV Design

Akuo Shingles





Google Mountain View HQ by BIG



Final Radiation



Yearly Results



$$2136 \text{ kWh/m}^2 \times 5300 \text{ m}^2 \times 0.86 \times 0.17 = 1\,655\,100 \text{ kWh per year}$$

Conclusion

Net Positive Building - EUI



60 Tucson Households